

MONTHLY PIPING INTERSTITIAL MONITORING RECORD

Louisiana Department of Environmental Quality
Underground Storage Tank and Remediation Division

		City:	Zip Code:
7	Type of Interstitial Mo	onitoring (i.e., float sensor, etc.)	
OK (√)	Alarm (V)	Reason for Alarm (i.e., wa	ter, fuel, etc.) and Corrective Action Taken
		Type of Interstitial Mo	City: Type of Interstitial Monitoring (i.e., float sensor, etc.)

NOTE: Product piping interstitial monitoring can be performed either continuously with sensors or every 30 days by visual inspection, in accordance with LAC 33:XI:701.B.4. Three years of monthly release detection records must be maintained in accordance with LAC 33:XI.705.A.2. If the electronic interstitial monitoring method used does not provide records, this form may be used to document the readings on the electronic monitor once every 30 days. If a release is indicated, source of the product must be investigated and corrective action taken to address the leak in accordance with LAC 33:XI:711. If a suspected release of product has occurred, it must be reported to Louisiana Department of Environmental Quality (LDEQ) Single Point of Contact (SPOC) within 24 hours at 225-219-3640 or 888-763-5424 in accordance with LAC 33:XI:707.A.